



STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0016

Paul R. LePage  
GOVERNOR

David Bernhardt  
COMMISSIONER

September 2, 2011  
Location: **Skowhegan**  
State Pin No: **017539.00**  
**Amendment No. 1**

Dear Sir/Ms:

The following question has been received:

**Question:** The Project specification does not refer to any pipe lining material type. What pipe specification will be used for this project?

**Response:** Either plastic or corrugated metal pipe.

Consider this information prior to submitting your bid on September 7, 2011.

Sincerely,

*For* Scott Bickford  
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER